



## Micro40 Slot Accent SuperSpot



40mm (1.57") overall diameter. Fully recessed Micro40 downlight for interior installation. 45° tilt max (20° with 12.5mm ceiling and standard cut-out). Family of matching products also available. Required depth height + 10mm<sup>^</sup>



M43-SA-SS-TR  
Cut-out 36mm Ø



M43-SA-SS-TL  
Cut-out 37mm Ø

|                         |         |
|-------------------------|---------|
| LED Source              | LED     |
| CCT                     | 3000K   |
| Drive Current           | 350mA   |
| Power inc Driver        | 4.65W   |
| Beam Angle              | 10°     |
| Delivered Lumens        | 72      |
| Delivered Intensisty cd | 1923    |
| Efficacy lm/w           | 16      |
| Forward Volt            | 11.3V   |
| CRI                     | ≥90 CRI |

Project Ref: \_\_\_\_\_

Location Ref: \_\_\_\_\_

Fixture Order Code: **M43-SA-SS** - [ ] - [ ] - [ ] - 10 - 350 - [ ]

Fixture  
M43-SA-SS      Micro40 Slot Accent SuperSpot

Installation  
TR      Trim  
TL      Trimless


CCT  
27      90 CRI 2700K  
30      90 CRI 3000K  
40      90 CRI 4000K

Finish  
WH      White  
BK      Black

Beam  
10      10°

Drive Current  
350      350mA

Protocol  
S      Non-Dim  
A      Analogue (0-10v)  
P      Phase  
D      DALI  
B      Bluetooth\*\*



## Technical Details

\*Custom RAL code must be specified. Custom RAL colours can increase prices and lead times

Dimming. Whilst Lucent can offer the majority of its luminaires with various dimming options, it remains the responsibility of the specifier/installer to check and ensure compatibility of any control equipment used. Additional cabling may be required depending on the dimming protocol specified.

\*\*Bluetooth (wireless) is the communication method. The exact dimming protocol must be confirmed to allow the selection of suitable drivers or bluetooth devices.

^ Depth indicated is the minimum recess depth for the luminaire with a remote mounted LED driver. Installing a driver through either the luminaire cut-out or installation kit may require additional recess depth, please refer to the relevant luminaire installation instructions for further details. Data correct at time of publishing

First Fix Requirement. Luminaire comprised of fixture body with ceiling trim and installation kit, which is to be fitted into the ceiling once finished. Ensure correct alignment of the installation kit before final assembly (see luminaire installation instructions for details)

IP Rating. Tested from underside of the ceiling

It is the policy of Lucent Lighting to continually review and improve its products and therefore reserve the right to change any details of product or withdraw specifications without prior notice.

Luminaires designed to comply with EN60598 and all other standards.

This specification sheet supersedes all previous versions.

All intellectual property rights pertaining to the product described above and to this document are owned by or licensed to Lucent Lighting Ltd.

We reserve the right to take whatever action is necessary to protect those intellectual property rights.

Please notify Lucent Lighting Ltd of any inaccuracies immediately. E&OE